

Attestation No.: HS5200-230628JH08-SF-LD

Date of issue: 2023-10-17

Issued To: Wuxi Solinteg Power Co., Ltd.

Applicant Address: Building H1-1001, No. 6 Jingxian Road, Xinwu District, 214135Wuxi, Jiangsu Province, China

Product(s): Hybrid Inverter

Brand(s): **SOLINTEG**

Model(s): MHT-4K-25; MHT-5K-25; MHT-6K-25; MHT-8K-25;
MHT-10K-25; MHT-12K-25; MHT-10K-40; MHT-12K-40;
MHT-15K-40; MHT-20K-40;

Power Characteristics: See Annex A on page 2

We, Hwa-Hsing (Dongguan) Testing Co., Ltd.,

Declare that the submitted sample of the above has been tested for CE marking according to following standard(s) of the European Directive:

- **Low Voltage Directive (LVD) 2014/35/EU**

	Standards	Report No.
Safety requirements for power electronic converter systems and equipment - Part 1: General	EN 62477-1:2012, EN 62477-1:2012/A11:2014, EN 62477-1:2012/A1:2017, EN 62477-1:2012/A12:2021 IEC 62477-1:2022	230628JH08-SF-LD

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements.

This ATTESTATION does not imply assessment of the production of the product.

Supplementary information:



Winter Liu

Winter Liu
Safety Supervisor

Model/Type reference..... :	MHT-4K-25 ¹⁾ , MHT-5K-25 ²⁾ , MHT-6K-25 ³⁾ , MHT-8K-25 ⁴⁾ , MHT-10K-25 ⁵⁾ ; MHT-12K-25 ⁶⁾ , MHT-10K-40 ⁷⁾ , MHT-12K-40 ⁸⁾ , MHT-15K-40 ⁹⁾ , MHT-20K-40 ¹⁰⁾
Max. PV input voltage [Vdc]..... :	1000
PV MPPT voltage range [Vdc]..... :	120-950 ^{1), 2), 3)} ; 200-950 ^{4), 5), 6), 7), 8), 9), 10)}
Max. PV input current [Adc]..... :	15/15 ^{1), 2), 3), 4), 5), 6)} ; 30/30 ^{7), 8), 9), 10)}
Max. PV short-circuit current (Adc) :	20/20 ^{1), 2), 3), 4), 5), 6)} ; 40/40 ^{7), 8), 9), 10)}
Battery voltage range[Vdc]	135-750
Battery type..... :	Lithium Battery
-Maximum charging current (A)	25 ^{1), 2), 3), 4), 5), 6)} ; 40 ^{7), 8), 9), 10)}
-Maximum discharge current (A)	25 ^{1), 2), 3), 4), 5), 6)} ; 40 ^{7), 8), 9), 10)}
Nominal input AC voltage [V]..... :	380/400 (3W + N + PE)
Nominal output AC voltage [V]	380/400 (3W + N + PE)
Max. input AC current [A]..... :	11.6 ¹⁾ /14.5 ²⁾ /17.4 ³⁾ / 23.2 ⁴⁾ / 23.9 ⁵⁾ / 23.9 ⁶⁾ / 29.0 ⁷⁾ / 34.8 ⁸⁾ / 43.5 ⁹⁾ / 43.5 ¹⁰⁾
Max. output AC current [A]	6.7 ¹⁾ / 8.3 ²⁾ / 10.0 ³⁾ / 13.3 ⁴⁾ / 16.5 ⁵⁾ / 20.0 ⁶⁾ / 16.5 ⁷⁾ / 20.0 ⁸⁾ / 25.0 ⁹⁾ / 33.5 ¹⁰⁾
Rated AC output power [kW]..... :	4 ¹⁾ / 5 ²⁾ / 6 ³⁾ / 8 ⁴⁾ / 10 ⁵⁾ / 12 ⁶⁾ / 10 ⁷⁾ / 12 ⁸⁾ / 15 ⁹⁾ / 20 ¹⁰⁾
Max. apparent AC output power [kVA] :	4.4 ¹⁾ / 5.5 ²⁾ / 6.6 ³⁾ / 8.8 ⁴⁾ / 11 ⁵⁾ / 13.2 ⁶⁾ / 11 ⁷⁾ / 13.2 ⁸⁾ / 16.5 ⁹⁾ / 22 ¹⁰⁾
Nominal input frequency [Hz]..... :	50/60
Nominal output frequency [Hz]	50/60
Firmware version / Software version :	V1.00/V1.00



Winter Liu

Winter Liu
Safety Supervisor