

Certificate No.: **LS250046GCC-0**

Date of issue: 2025-05-09

Valid until: Indefinitely

Applicant:	Wuxi Solinteg Power Co., Ltd. Building H1-1001, No. 6 Jingxian Road, Xinwu District, 214135 Wuxi, Jiangsu Province, China
Product:	Hybrid Inverter
Model(s):	M2HT-25K-150, M2HT-29.9K-150, M2HT-30K-150, M2HT-40K-150, M2HT-50K-150
Trademark:	SOLINTEG
Technical data:	Nominal active output power [kW]: 25 ~ 50 Nominal output AC voltage [V]: 230V / 400 V (3L + N + PE, 50 / 60 Hz) (For further details see A.2 on p.2)
Software version:	V1.00
Applied standard(s) / guideline(s):	IEC 60068-2-1:2007 Environmental testing - Part 2-1: Tests – Test A: Cold IEC 60068-2-2:2007 Environmental testing - Part 2-2: Tests – Test B: Dry heat IEC 60068-2-14:2023 Environmental testing - Part 2-14: Tests – Test N: Change of temperature IEC 60068-2-30:2005 Environmental testing - Part 2-30: Tests – Test Db and guidance: Damp heat, cyclic (12 + 12-hour cycle) IEC 60068-2-64:2008 Environmental testing - Part 2-64: Tests – Test Fh: Vibration, broadband random and guidance IEC 61683:1999, EN 61683:2000 Photovoltaic systems - Power conditioners - Procedure for measuring efficiency IEC 61727:2004 Photovoltaic (PV) systems - Characteristics of the utility interface IEC 62116:2014, EN 62116:2014 Utility-interconnected photovoltaic inverters - Test procedure of islanding prevention measures
Certification scheme:	CMPD-01
Test report no.:	HC2412270309GC01 (2025-04-27) HC2412270309GC02 (2025-04-27) HC2412270309GC03 (2025-04-27) VTL25.01.040E (2025-02-26)

This certificate confirms that the above-mentioned generating unit(s) with corresponding software meet the requirements of the referenced standard(s) / guideline(s) at the time of issuance of the certificate.

This certificate relates to type testing and does not imply LYNS's endorsement, approval, certification or on-going control of the product(s), either in terms of performance, design, manufacture or materials used. This certificate and the results stated herein relate solely to the sample product(s) tested and to the specific tests undertaken.

The certificate will remain valid for the stated period providing no changes are made to the product, production method etc. This certificate is only valid when this is also found at <http://www.lyns-tci.com/en/certificate-search> or contact Lyns-tci Technology Guangdong Co., Ltd..

This certificate is for the exclusive use of LYNS's Client and is provided pursuant to the agreement between LYNS and its Client. LYNS's responsibility and liability are limited to the terms and conditions of the agreement. LYNS assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned using this verification.

The certificate is comprised of 2 pages (including Annex of 1 pages).

Dongguan, 2025-05-09

Dipl.-Ing. Weizhao Zheng
Head of certification body

Certification body Lyns-tci Technology Guangdong Co., Ltd. accredited according to ISO/IEC 17065 for product certification.

This document shall not be reproduced, except in full, without the written approval of Lyns-tci Technology Guangdong Co., Ltd.

A.1 Revision history of the certificate

Rev. No.	Date	Changes	Status
Rev. 0	2025-05-09	Initial issue	Active

A.2 Technical data of the power generating unit(s)

Model	M2HT-25K-150	M2HT-29.9K-150	M2HT-30K-150	M2HT-40K-150	M2HT-50K-150
Input PV (DC)					
Max. DC input voltage [V]	1000				
Operating MPPT voltage range [V]	200 ~ 950				
Max. input DC current [A]	40 A * 4				
Input Battery					
Battery voltage range (V)	150-840				
Max. charging/discharge current (A)	150				
Output (AC)					
Rated output AC voltage [V]	230V / 400V(3L + N + PE, 50 / 60 Hz)				
Max. Output AC current [A]	37.9	45.3	45.5	60.6	75.8
Rated active power [kW]	25	29.9	30	40	50
Max. apparent power [kVA]	25	29.9	30	40	50
Operating temperature range					
-30℃ ~ +60℃					
Degree of protection					
IP66 (according to EN 60529)					
Protection class					
I (according to IEC 62109-1)					
Over voltage category					
AC: III; DC: II (according to IEC 62109-1)					
Topology					
No galvanic isolation					
Software version					
V1.00					
Manufacturing factory					
Wuxi Solinteg Power Co., Ltd. No. 2 Xingchuang 1st Road, Xinwu District, Wuxi, Jiangsu Province, China					

A.3 Remarks for type testing

Testing laboratory	Lyns-tci Technology Guangdong Co., Ltd. Room 1201, Unit 2, Building 18, No. 7, Science and Technology Boulevard, Houjie Town, Dongguan City, Guangdong, 523960 P.R.C (Accredited acc. ISO/IEC 17025: A2LA Accreditation no. 5200.02)
Testing location	Same as above
Measurement period	2025-01-02 ~ 2025-04-17
Testing laboratory	Jiangsu Vehicle Testing Services Co., Ltd. Building 6, No.278, Huajin Road, Tongan, SND, Suzhou, Jiangsu, China (Accredited acc. ISO/IEC 17025: CNAS Accreditation no. L12681)
Testing location	Same as above
Measurement period	2025-01-17 ~ 2025-01-22